

**EirGrid plc**  
**HVDC Interconnectors**  
**Proposed Modifications to the Grid Code**  
**09 September 2009**

It is proposed to amend the Grid Code by adding in the text in blue and by deleting the text in red strikethrough:

**PC**      **PLANNING CODE**

**PC.3**      **SCOPE**

The **Planning Code** applies to the **TSO** and to the following **Users**:

- (a) **Generators** and **Generator Aggregators** with **Registered Capacity** greater than 10 MW;
- (b) all **Generators** connected to the **Transmission System**;
- (c) **Distribution System Operator**;
- (d) **Transmission Asset Owner**; ~~and~~
- (e) **Demand Customers** including both **Dispatchable Demand Customers** and **Demand Side Units**; and
- (f) **HVDC Interconnectors**.

The above categories of **User** will become bound by the **Planning Code** prior to generating, distributing or consuming electricity, as the case may be, and references to the various categories (or to the general category) of **User** should, therefore, be taken as referring to a prospective **User** in that role as well as to **Users** actually connected.

**PC.A4.14**    **HVDC Interconnector Characteristics and Registered Data**

Minimum technical, design and operational criteria to be met by **HVDC Interconnectors** are specified in the **Connection Conditions**.

For an **HVDC Interconnector** fill in the following:

**HVDC Interconnector Registered Import Capacity** for import to the **Transmission System** (MW)      \_\_\_\_\_

**HVDC Interconnector Registered Export Capacity** for export from the **Transmission System** (MW)      \_\_\_\_\_

## **CC CONNECTION CONDITIONS**

### **CC.3 SCOPE**

The **Connection Conditions** apply to the **TSO** and to the following **Users**:

- (a) **Generators** with **Registered Capacity** greater than 2MW;
- (b) The **Distribution System Operator**;
- (c) **Demand Customers**; ~~and~~
- (d) **Dispatchable Demand Customers**; and
- (e) The **HVDC Interconnectors**.

in relation to their connection to the **Transmission System**.

### **CC.5 PLANT DESIGNATIONS**

**CC.5.3** The **TSO's** standard practice currently requires that, unless otherwise agreed with the **TSO**, the following standard designations apply:

- (a) **Generation Units**  
and **HVDC Interconnectors**:
  - for hydro and wind: G1, G2 etc.
  - for thermal: U1, U2 etc.
  - for HVDC: I1, I2 etc.
- (b) **Generator transformers**
  - at 400 kV; T4001, T4002 etc.
  - (i.e. transformers for  
**Generation Unit** production) at 220 kV; T2001, T2002 etc.
  - at 110 kV; T101, T102 etc.and **HVDC Interconnector transformers**

### **CC.7.2.5 Grid Connected Transformers**

**CC.7.2.5.5** An **HVDC Interconnector Transformer** shall be designed such that the **Reactive Power** capability is possible over the full range of **Transmission System Voltages** (specified in CC.7.5.1.1 (f)). The **TSO** and an **HVDC Interconnector** owner will liaise on matters related to the **HVDC Interconnector Transformer** at the design stage.

CC.7.2.5.6 **HVDC Interconnector Transformer** windings shall be connected in star (with the star point or neutral brought out) on the higher **Voltage** side and in delta on the lower **Voltage** side or as agreed with the TSO.

## CC.7.5 **HVDC Interconnector**

CC.7.5.1 The conditions specified in this section of the code apply to all **HVDC Interconnectors** connected to or connecting to the **Transmission System**.

CC.7.5.1.1 Each **HVDC Interconnector**, shall have these minimum capabilities, for the avoidance of doubt, additional performance capabilities are required from **System Services**:

- (a) operate continuously at **MW Output** at **Transmission System Frequencies** in the range 49.5Hz to 50.5Hz;
- (b) operate and remain connected to the **Transmission System** at **Transmission System Frequencies** within the range 47.5Hz to 52.0Hz ;
- (c) remain connected to the **Transmission System** at **Transmission System Frequencies** within the range 47.0Hz to 47.5Hz for a duration of 30 seconds required each time the Frequency is below 47.5Hz;
- (d) remain synchronised to the **Transmission System** during rate of change of **Transmission System Frequency** of values up to and including 1 Hz per second;
- (e) remain connected to the **Transmission System** at **MW Output** at **Transmission System Voltages** within the ranges specified in CC.8.3.2 for step changes in **Transmission System Voltage** of up to 10%;
- (f) sustained operation in accordance with the **Reactive Power** capability referred to in OC4.8 at **Transmission System Voltages** within the ranges specified in CC.8.3.2, unless otherwise specified;
- (g) remain connected during and following **Voltage** dips at the **HV** terminals of the **HVDC Interconnector Transformer** of 95% of nominal **Voltage** (5% retained) for duration 0.2 seconds and **Voltage** dips of 50% of nominal **Voltage** (i.e. 50% retained) for duration of 0.6 seconds. Following the fault clearance the **HVDC Interconnector** should return to pre-fault conditions subject to normal frequency control and **Automatic Voltage Regulator** responses;
- (h) operate within all normal operating characteristics at a minimum short circuit level at the **Connection Point** of 1000 MVA;
- (i) remain connected to the **Transmission System** during a negative phase sequence load unbalance in accordance with IEC 60034-1;

- (j) have support triggers to allow the **HVDC Interconnector** to provide **System Services** as outlined in OC4.8;
- (k) in **Emergency** capable of reversing the power flow on the **HVDC Interconnector** at a rate which shall be no less than the **HVDC Interconnector Registered Capacity** within five seconds, up to ten times during the life of the plant and no more than two times in any given twelve months;
- (l) **HVDC Interconnector Minimum Load** not greater than the lesser of 3% of the **HVDC Interconnector Registered Capacity** or 50 MW;
- (m) **HVDC Interconnector Ramp-up Capability** not less than the greater of 10% of the **HVDC Interconnector Registered Capacity** per minute or 50 MW per minute, when the **HVDC Interconnector** is in the **Normal Dispatch Condition**;
- (n) **HVDC Interconnector Ramp-down Capability** not less than the greater of 10% of the **HVDC Interconnector Registered Capacity** per minute or 50 MW per minute, when the **HVDC Interconnector** is in the **Normal Dispatch Condition**;
- (o) **Forbidden Zones** within the lesser range of between + and - 3% of the **HVDC Interconnector Registered Capacity** or 30 MW in either flow direction and not more than 2 specified zones.
- (p) **Block Load for an HVDC Interconnector** not greater than the lesser of 3% of the **HVDC Interconnector Registered Capacity** or 30 MW in either flow direction.
- (q) **Time from off-line to HVDC Interconnector Minimum Load in either flow direction** Not greater than 30 minutes.
- (r) **Time from HVDC Interconnector Minimum Load in either flow direction to off-line** Not greater than 30 minutes.

CC.7.5.1.2 Where the **TSO** approaches an **HVDC Interconnector**, the **HVDC Interconnector** will co-operate with the **TSO** in the development of procedures and facilities to improve the response of each **HVDC Interconnector** during conditions of system stress. This shall be subject to the agreement of the **HVDC Interconnector** that the procedures are consistent with secure operation of the **HVDC Interconnector's Plant**, such agreement not to be unreasonably withheld.

CC.7.5.2 The **HVDC Interconnector** station owner must ensure that the reversal of flow capabilities are provided for such that the average **HVDC Interconnector Ramp Rate** from **HVDC Interconnector Registered Export Capacity** to **HVDC Interconnector Minimum Import Load** or **HVDC Interconnector Registered Import Capacity** to the **HVDC Interconnector Registered Export Capacity** of at least 50 MW per minute. For the avoidance of doubt this aggregate **HVDC Interconnector Ramp Rate** will include any time needed to pass through deadbands or **Forbidden Zones** of operation.

CC.7.5.3 The **HVDC Interconnector** will be able to connect to the transmission system under the following conditions:

- (a) **Transmission System Frequency** within the limits 48.0 to 52.0 Hz;
- (b) **Transmission System Voltage** within the limits as specified in CC.8.3.2, not withstanding CC.7.5.9;
- (c) **Transmission System Short Circuit Level** at the point of connection no less than 1000 MVA.

Where supply from the **Transmission System** is temporarily lost, **HVDC Interconnectors** must be able to reconnect to the **Transmission System** and reach **Minimum Load** within 30 minutes of the **Transmission System** supply being restored.

CC.7.5.4 Each **HVDC Interconnector**:

- a) must ensure that they do not cause any sub synchronous resonance, undamped oscillations or harmful shaft torsional oscillations on existing generators on the **Transmission System**. Where it is determined that

the **HVDC Interconnector** does cause such oscillations or resonances a solution to remove these shall be agreed with the **TSO**.

- b) where further studies are required to examine an oscillation or resonance issue there shall be an exchange of the necessary data between the **HVDC Interconnector** and the **TSO**, such exchange of data shall not be unreasonably withheld. The **HVDC Interconnector** shall provide a report to show the contribution that the **HVDC Interconnector** control system design will have on the torsional mode frequencies.

Input provisions for addition of a future sub synchronous damping controller shall be made by the **HVDC Interconnector**.

- c) shall provide controls to damp power oscillations on the AC network.

CC.7.5.5 Each **HVDC Interconnector** must be capable of:

- a) contributing to **Frequency Control** by continuous modulation of **Active Power** supplied to the **Transmission System**;
- b) contributing to **Voltage Control** by continuous changes to the **Reactive Power** supplied to the **Transmission System**;


CC.7.5.6 **Users** shall install **HVDC Interconnector** controllers that comply with OC4.8. **Users** shall not change frequency or load related control settings of the **HVDC Interconnector** controllers without agreement with the **TSO**.

CC.7.5.7 **Standards for Frequency Control**

CC.7.5.7.1 Each **HVDC Interconnector** must be fitted with a fast acting control device to provide frequency response under normal operating conditions in accordance with OC4. The control device must be designed and operated to the appropriate

- (a) European Standards; or
- (b) In the absence of a relevant European Standards, such other standard which is in common use within the European Union.

CC.7.5.7.2 An **HVDC Interconnector** must be capable of maintaining its **Active Power** input (i.e. when operating in a mode analogous to **Demand**) from the **Transmission System** at a level not greater than the amount determined by the linear relationship shown in the figure below for **System Frequency** changes within the range  $f_1$  to  $f_2$  Hz, such that if the **System Frequency** drops to  $f_1$  Hz the **Active Power** input decreases by more than  $100 - P_1$  where  $P_1$  is the upper active power limit as a percentage of the **Active Power** output before the frequency change event.




Settings for each of  $f_1$ ,  $f_2$  and  $P_1$  shall be specified by the **TSO** at least 120 **Business Days** prior to the **HVDC Interconnector's** scheduled **Operational Date**. The **HVDC Interconnector** shall be responsible for implementing the appropriate settings during **Commissioning**.

Alterations to these settings may be requested in real-time by the **TSO** and the implementation of the settings shall commence within 10 seconds of receipt of the signal from the **TSO**.

#### CC.7.5.8 **HVDC Interconnector Frequency Control**

CC.7.5.8.1 An **HVDC Interconnector** must be capable of maintaining its **Active Power** output (i.e. when operating in a mode analogous to **Generation**) into the **Transmission System** at a level not lower than the amount determined by the linear relationship shown in the figure below for **System Frequency** changes within the range  $f_3$  to  $f_4$  Hz, such that if the **System Frequency**

drops to  $f_4$  Hz the **Active Power** input decreases by no more than  $100 - P_3$  where  $P_3$  is the lower **Active Power** limit as a percentage of the **Active Power** output before the frequency change event.



Settings for each of  $f_3$ ,  $f_4$  and  $P_3$  shall be specified by the **TSO** at least 120 **Business Days** prior to the **HVDC Interconnector's** scheduled **Operational Date**. The **HVDC Interconnector** shall be responsible for implementing the appropriate settings during **Commissioning**.

Alterations to these settings may be requested in real-time by the **TSO** and the implementation of the settings shall commence within 10 seconds of receipt of the signal from the **TSO**.

CC.7.5.8.2 At the **Grid Connection Point** the **Active Power** output under steady state conditions of any **HVDC Interconnector** directly connected to the **Transmission System** should not be affected by **Voltage** changes in the normal operating range specified by more than the change in **Active Power** losses at reduced or increased **Voltage**. The **Reactive Power** output under steady state conditions should be fully available at normal operating range.

CC.7.5.8.3 The **Frequency Deadband** for all **HVDC Interconnectors** should be no greater than 0.03Hz (for the avoidance of doubt,  $\pm 0.015$ Hz);


CC.7.5.9 **Standards for Reactive Control**

CC.7.5.9.1 All **HVDC Interconnectors** (excluding **Current Source Technology**) shall

be capable of contributing to control of **Transmission System Voltage** by continuous modulation of **HVDC Interconnector Voltage** by means of a suitable continuously acting **Automatic Voltage Regulation (AVR)** which shall be in accordance with **Voltage Regulation Grade VR2.33 of BS4999 part 140**, or equivalent European Standards and the characteristics of which have been accepted by the **TSO** prior to the **Connection Date**, such acceptance not to be unreasonably withheld.

#### CC.7.5.10 **HVDC Interconnector Reactive Power**

- a) There is a requirement for a continuously-acting automatic control system to provide control of the **Voltage** (or zero transfer of **Reactive Power** as applicable) at the **Grid Connection Point** without instability over the entire operating range of the **HVDC Interconnector**.
- b) **HVDC Interconnector** must be capable of maintaining zero transfer of **Reactive Power** at the **Grid Connection Point** at all **Active Power** output levels under steady state **Voltage** conditions. The steady state tolerance on **Reactive Power** transfer to and from the **Transmission System** expressed in MVar shall be no greater than 5% of the rated MW.
- c) An **HVDC Interconnector** (excluding **Current Source Technology**) must be capable of supplying rated MW input/output at any point between the limits 0.95 Power Factor lagging and 0.95 Power Factor leading at the **Connection Point**.



Point A is equivalent (in MVar) to:	0.95 leading <b>Power Factor</b> at rated MW output
Point B is equivalent (in MVar) to:	0.95 lagging <b>Power Factor</b> at rated MW output
Point C is equivalent (in MVar) to:	-5% of rated MW output
Point D is equivalent (in MVar) to:	+5% of rated MW output
Point E is equivalent (in MVar) to:	-12% of rated MW output

## **CC.10.12 Power Quality**

CC.10.12 .3 **HVDC Interconnectors** shall ensure that their connection to the **Transmission System** does not result in the level of distortion or fluctuation of the supply **Voltage** on the **Transmission System**, at the **Connection Point**, exceeding that allocated to them. These limits will be determined by the **TSO** during discussions with the **HVDC Interconnector**, where the necessary data will be exchanged between both parties, the exchange of data shall not be unreasonably withheld. This data may consist of impedance loci at the **Connection Point** and the **HVDC Interconnector** harmonic current emissions. Distortion and fluctuation limits are outlined in IEC/TR3 61000-3-6 (Harmonics) and IEC/TR3 61000-3-7 (Voltage fluctuation). **HVDC Interconnectors** shall also operate their **Plant** in a manner which will not cause the requirements in CENELEC Standard EN 50160 to be breached.

The **HVDC Interconnector** cannot be connected to the **Transmission System** until:

- (a) the required harmonic studies have been completed by the **HVDC Interconnector** to show compliance with the standards outlined above and reviewed by the **TSO**;
- (b) any appropriate remedies to enable the **HVDC Interconnector** to operate with harmonic distortion levels within agreed limits have been identified and implemented with the **TSO**.

CC.10.12.4 The harmonic voltage distortion emission limits and any special conditions pertaining to the quality of supply must be included in the **Connection Agreement**, and are subject to verification of compliance by the **TSO** through an ongoing approved monitoring programme to be implemented by the **HVDC Interconnector**.

## **CC.10.13 HVDC Interconnector Transformer**

CC.10.13.1 **HVDC Interconnector** shall provide:

- (a) differential protection on the **HVDC Interconnector Transformer**. The connections between the **Grid Connection Point** circuit breaker

and the **HV** terminals of the **HVDC Interconnector Transformer** shall be included in the protected zone of this differential protection.

- (b) backup protection (to the **Transmission System**) on **HVDC Interconnectors**. The **TSO** acting reasonably shall require one or more of the following to be installed: **HVDC Interconnector** overcurrent protection, **Voltage** controlled **HVDC Interconnector** overcurrent protection or **HVDC Interconnector** distance protection;
- (c) under **Frequency** protection; and

CC.10.13.2 The **TSO** may require an individual **HVDC Interconnector**, to install additional protection and/or control schemes, where the **TSO** can reasonably show that it is prudent or necessary to do so. These schemes may include but are not limited to the following:

- (a) **HVDC Interconnector** over/under-voltage protection.
- (b) **HVDC Interconnector** over-frequency protection.
- (c) **Power System** stabiliser.

CC.10.13.3 Distance protection shall be provided by the **TSO** on the **Grid Connection Point** circuit breaker of **HVDC Interconnector Transformers**.

## CC.12 SIGNALS TO BE PROVIDED BY USERS

CC.12.2

(s), (t) and (u) are applicable to **HVDC Interconnector** owners:

- (s) +/-MW and +/-Mvar at the terminals of the **HVDC Interconnector** ;
- (t) kV at **HVDC Interconnector Transformer LV** terminals;
- (u) **HVDC Interconnector Transformer** tap position;

### Changes to Glossary:

#### Block Load for an HVDC Interconnector

The level of output, in either flow direction, that an **HVDC Interconnector** immediately produces following **Synchronisation**. For avoidance of doubt, **Block Load** can equal 0 MW and can be different in either flow direction.

#### Current Source Technology Forbidden Zones

\*Christian to provide a definition\*

A MW range within which a **Generator or HVDC Interconnector** cannot operate in a stable

	manner due to an inherent technical limitation of the apparatus or plant.
<b>Grid Connection Point</b>	The point at which a <b>Generating Unit</b> or a <b>CCGT Installation</b> or a <b>CCGT Unit</b> or an <b>HVDC Interconnector</b> or a <b>Customer</b> or an <b>External System</b> , is directly connected to the <b>Transmission System</b> .
<b>HVDC Interconnector</b>	<b>DC</b> electrical transmission system as a means for the bulk transmission of electrical power from one <b>User</b> system to another.
<b>HVDC Interconnector Minimum Export Load</b>	Minimum MW output an <b>HVDC interconnector</b> can export continuously to a remote network while maintaining stability
<b>HVDC Interconnector Minimum Import Load</b>	Minimum MW output an <b>HVDC interconnector</b> can import continuously from a remote network while maintaining stability
<b>HVDC Interconnector Minimum Load</b>	Absolute sum of the <b>HVDC Interconnector Minimum Export Load</b> and <b>HVDC Interconnector Minimum Import Load</b> representing the minimum range of bi-directional power transfer.
<b>HVDC Interconnector's Plant</b>	An <b>HVDC Interconnector</b> station subject to <b>Central Dispatch</b>
<b>HVDC Interconnector Ramp-down Capability</b>	The rate of decrease of an <b>HVDC Interconnector</b> . <b>Ramp-down Capabilities</b> apply over the bi-directional range from its <b>HVDC Interconnector Registered Import Capacity</b> to its <b>HVDC Interconnector Registered Export Capacity</b> .
<b>HVDC Interconnector Ramp-up Capability</b>	The rate of increase of an <b>HVDC Interconnector</b> . <b>Ramp-up Capabilities</b> apply over the bi-directional range from its <b>HVDC Interconnector Registered Export Capacity</b> to its <b>HVDC Interconnector Registered Import Capacity</b> .
<b>HVDC Interconnector Ramp Rate</b>	The maximum rate of increase or decrease of the power transferred, in either flow direction, by an <b>HVDC Interconnector</b> .
<b>HVDC Interconnector Registered Capacity</b>	The maximum <b>Capacity</b> , in either flow direction, expressed in whole MW, that an <b>HVDC Interconnector</b> can deliver on a sustained basis, without accelerated loss of equipment life, at the <b>Connection Point</b> .
<b>HVDC Interconnector Registered Export Capacity</b>	The maximum <b>Capacity</b> , expressed in whole MW that an <b>HVDC Interconnector</b> may export (transfer energy from the <b>Power System</b> to a remote network) on a sustained basis, without accelerated loss of equipment life, as registered with the <b>TSO</b> .
<b>HVDC Interconnector Registered Import Capacity</b>	The maximum <b>Capacity</b> , expressed in whole MW that an <b>HVDC Interconnector</b> may import (transfer energy from a remote network into the <b>Power System</b> ) on a sustained basis, without accelerated loss of equipment life, as registered with the <b>TSO</b> .
<b>HVDC Interconnector Transformer</b>	A transformer whose principal function is to provide the interconnection between the <b>HVDC Interconnector</b> and the Network and to

transform the **HVDC Interconnector** voltage to the Network voltage.