

# Review of the Power System

Michael Power  
15<sup>th</sup> October 2008



# Presentation Structure

- System statistics
- Challenges for system operation
  - Frequency Excursions
  - Wind and Transmission Outages
  - Winter Peak and Moyle



# System Statistics




# Summary System Statistics

Generating Plant (excl. wind)	6200 MW
Generating Stations	21
Energy 2007	28 TWh
Energy Growth 2007 over 2006	2.6%
Energy Growth to August 31 <sup>st</sup>	2.7%
Load variation from	1786 to 4906 MW
<i>Max/Min ratio of 2.7</i>	


*(See 'System Records' under 'System Operations' on [WWW.EirGrid.Com](http://WWW.EirGrid.Com))  
All figures are exported MW/MWh*



# % Fuel Mix 2007



# Gas - % System Demand




## Wind Statistics

- Wind Generating Capacity 915 MW
- Wind farms 85
- Capacity by end 2008 ~1000 MW
- Peak wind output (Sept 10) 770 MW
- Approx. 48% are transmission connected




# Wind % of System Demand




# System Disturbances




# Loss of 400 MW Unit on July 10th



# Example of Poor Response



# Turlough Hill's Response



## Observations on July 10th


- Did not shed load.
- Moyle reserve was triggered at 49.6Hz
- Poor delivery of reserve by main providers especially Tertiary Operating Reserve 1&2 (*90 – 1200 seconds*).
- Typical response - majority of reserve provided by Turlough Hill and OCGTs with minimal contributions from CCGTs and other thermal generators.




# Wind and Transmission Outages



# Wind – Sept 16 vs. Sept 17



# Wind and Transmission Outages – Sept 16 & 17



# Issues Arising

- 10% overload expected from studies on 16<sup>th</sup>. 25% overload in reality on day of outage.
- Outage had to take place overnight. This was only a 4 hour outage.
- Even with accurate modelling of every wind farm, it is impossible to study all generation scenarios, say, for a 4 week outage.
- Must have accurate wind forecasting for each region - cluster of wind farms.
- If installing generation to replace wind during low wind generation periods then site selection is critical.



# Winter Peak




## Winter Peak 2008/9

- Estimate 5125 exported / 5305 generated
- Highly temperature dependent!
- Increase of 220 MW over 2007/8
- In comparison to last year's dispatch this would be covered by availability of MP3 or additional wind.
- No significant plant changes since last winter. AP5 has become TP3.



## Moyle Interconnector Flow at Weekly Peak Demand for Last Three Winters (National Grid Winter Consultation Report (June) 2008/9)



**Thank You.**

