

Grid Code

CC.8.6 Item (d) List

Under CC.8.6 item (d) in the Grid Code (Version 3.4), the Transmission System is designed and operated to maintain the Initial Symmetrical Short-Circuit Current below 31.5 kA at designated locations on the 110 kV system. The list of the designated 31.5 kA locations is shown below. This list shall be published at least annually by the TSO.

31.5 kA Designated Locations on the 110 kV System
Barnahely
College Park
Corduff
Finglas
Kilbarry
Knockraha
Louth
Marina
Raffeen
Tarbert
Trabeg

Grid Code (Version 3.4):

<http://www.eirgrid.com/media/EirGrid%20Grid%20Code%20Version%203.4.pdf>

Document Version	1.0
Date of Current Issue	06-07-2010
Date of Next Update	04-07-2011