

## **MPID 186 – Transmission System Performance**

**Grid Code Version:** 3.1

**Grid Code clause number:** CC.8.6

**Proposed by:** EirGrid

### ***Modification Proposal:***

This modification proposal is raised by EirGrid. It is a typing error. The words 'Initial Symmetrical Short-Current Circuit' should read 'Initial Symmetrical Short-Circuit Current'.

It is therefore proposed to amend CC.8.6 by interchanging the words 'Current' and 'Circuit', as follows:

CC.8.6 The **Transmission System** is designed and operated to maintain the **Initial Symmetrical Short-Circuit Current** below the following:

- (a) 50kA on the 400kV system;
- (b) 40kA on the 220kV system;
- (c) 25 kA on the 110 kV system generally;
- (d) 31.5 kA at designated locations on the 110kV system.

The **TSO** shall notify any **User** with a connection to the **Transmission System** at a location to which item (d) above applies that the location is so designated.

The **TSO** shall publish annually a list of locations designated in accordance with item (d) above.