

| MPID | Section | Clause                | Modification   | Date Received | GCRP Meeting No | Comments  | Approved by CER | Date approved by CER |
|------|---------|-----------------------|--|---------------|-----------------|---|-----------------|----------------------|
| 101  | CC      | 12.2                  | New wording of new point (ba) to be proposed as follows: (ba) +/- MW and +/- MVAR at transformer low Voltage terminals             | 05/03/2001    | 3               | new text proposed at GCRP10   | Yes             | 15/11/2004           |
| 115  | OC9     | 4.1                   | Replace 'Regional Control Centre' with 'Distribution Control Centre'   | 08/04/2002    | 6               |   | Yes             | 01/07/2003           |
| 117  | OC10    | 4.4.2 (c)             | Add new text as follows: "Tertiary Operating Reserve 2 and Replacement Reserve provided by each of a Generator's Generation Units" | 27/09/2002    | 7               |   | Yes             | 08/09/2004           |
| 118  | SDC2A   | 3.1.2                 | Change from MVAR output to <b>MVAR Output  | 09/10/2002    | 7               |   | Yes             | 08/09/2004           |
| 119  | CC      | 7.3.7                 | Delete 'a' in 'as at a the time when the installation of which'  | 09/10/2002    | 7               |   | Yes             | 08/09/2004           |
| 120  | OC3     | 4                     | Modification to allow NTF, TRM, TTC, ATC, NTC and EPF to be published on the TSO website   | 27/11/2002    | 7               |   | Yes             | 08/09/2004           |
| 122  | CC      |                       | To set out the rules for CDGU- This includes changes to various clauses  | 04/03/2003    | 6               | all approved with exception of SDC2.7.7   | Yes             | 01/07/2003           |
| 123  | OC3     | 2.1                   | Insert 'to' in OC3 is to manage  | 04/03/2003    | 7               |   | Yes             | 08/09/2004           |
| 124  | PCA     | PCA6                  | Revise in accordance with SLR  | 21/05/2003    | 8               |   | Yes             | 04/02/2005           |
| 126  | PCA     | PCA4.10.1             | Addition of Wind Generators Dynamic Modelling Requirements following CER direction July 04   | 25/08/2004    | 10              | Text available on EirGrid website <a href="#">here</a>  | Yes             | 23/12/2004           |
| 127  | CC      | 12.4                  | Delete the words 'under the Connection Agreement'  | 01/09/2004    | 10              |   | Yes             | 15/11/2004           |
| 128  | PC      | 4.4.3                 | Amend to capture unit de-ratings by adding in the words de-rate before 'close'   | 31/08/2004    | 10              | Confirmed to be approved by CER on 04/02/05   | Yes             | 15/11/2004           |
| 129  | GC      | GCRP Constitution 6.6 | Amending the Constitution to hold member elections every 2 years instead of 1  | 31/08/2004    | 10              |   | Yes             | 15/11/2004           |
| 131  | SDC2A   | 3; 3.1; 3.2.1; 3.3    | Change incorrect numbering SCD2A.3 to SDC2A.3; SCD2A.3.1 to SDC2A.3.1; SCD2A.3.2.1 to SDC2A.3.2.1; SCD2A3.3 to SDC2A3.3;           | 31/08/2004    | 10              |   | Yes             | 15/11/2004           |
| 132  | GC      | All                   | Change 'VAR' to 'var'. This includes changing 'MVAR' to Mvar and 'kVAR' to 'kvar'.   | 31/08/2004    | 10              | The IEC (International Electrotechnical Commission) have defined the term for reactive power as 'var'. <a href="#">Source</a> | Yes             | 15/11/2004           |